



March 8, 2023

Village of Canwood
Box 172
Canwood, SK
S0J 0K0

Dear Waterworks Owner/Operator:

RE: Rescinding of Precautionary Drinking Water Advisory

The Water Security Agency, in consultation with the Saskatchewan Health Authority-Prince Albert Office, are advising that the ***“Precautionary Drinking Water Advisory”***(PDWA) issued by the Water Security Agency for Canwood’s potable water system be rescinded immediately.

The rescinding of the PDWA was based upon information provided by your community, which included:

- The system repairs have been completed;
- Chlorine residuals throughout the WTP and distribution system are within regulatory requirements; and
- Bacteriological sampling is within regulatory limits.

Your community may return to normal monitoring requirements as identified in your permits monitoring schedule.

In closing, I would like to acknowledge that the Water Security Agency appreciates the efforts and cooperation demonstrated by staff at your water treatment plant, as well as officials of the Village of Canwood in addressing the advisory.

Should you have any questions or concerns, please call me at (306) 921-7395.

Sincerely,

A handwritten signature in black ink that reads "Ries Mansuy".

Ries Mansuy, A.Sc.T.
Sr. Environment Officer
Water Security Agency – Science and Licensing Services Division
Nipawin, SK.

CC. Greg Holovach, Water Security Agency
Saskatchewan Health Authority-Prince Albert Office
Water Security Agency, Regina