

Drinking Water Quality and Compliance Village of Canwood – Annual Notice to Consumers

Introduction

The Water Security Agency and the Ministry of Environment requires that at least once each year waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the waterworks in submitting samples as required by a Minister's Order or Permit to Operate a waterworks. The following is a summary of the Village of Canwood water quality and sample submission compliance record for the **January 1 to December 31, 2022**, time period. This report was completed on January 09, 2023. Readers should refer to Water Security Agency's Municipal Drinking Water Quality Monitoring Guidelines, June 2015, EPB 502 for more information on minimum sample submission requirements and the meaning of type of sample. Permit requirements for a specific waterworks may require more sampling than outlined in the department's monitoring guidelines. If consumers need more information on the nature and significance of specific water tests, for example, "what is the significance of Selenium in a water supply", more detailed information is available from: http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index_e.html.

Water Quality Standards

Bacteriological Quality

Parameter/Location	Limit	Regular Samples Required	Regular Samples Submitted	# of Positive Regular Submitted (%)
Total Coliform	0 Organisms/100 mL	24	24	0 (0%)
E. coli	0 Organisms/100 mL	24	24	0 (0%)
Background Bacteria	Less than 200/100 mL	24	24	0 (0%)

Raw Water Bacteriological Quality

Parameter/Location	Limit	Regular Samples Required	Regular Samples Submitted	# of Positive Regular Submitted (%)
Total Coliform	0 Organisms/100 mL	12	12	0 (0%)
E. coli	0 Organisms/100 mL	12	12	0 (0%)
Background Bacteria	Less than 200/100 mL	12	12	0 (0%)

Water Disinfection –

Chlorine Residual in Distribution System for Test Results Submitted with Bacteriological Samples

Parameter	Minimum Limit	Total Chlorine Residual Range	Free Chlorine Residual Range	# Tests Required	# Tests Submitted	# Adequate Chlorine (%)
Chlorine Residual	0.1 mg/L free OR 0.5 mg/L total	0.78 to 1.36	0.47 to 1.06	24	24	24 (100%)

Water Disinfection –

Free Chlorine Residual for Water Entering Distribution System from Waterworks Records-from Water Treatment Plant Records

Parameter	Limit (mg/L)	Test Level Range	# Tests Performed	# Tests Not Meeting Requirements
Free Chlorine Residual	at least 0.1	0.38 to 2.32	365	0

A minimum of 0.1 milligrams per litre (mg/L) free chlorine residual is required for water entering the distribution system. Tests are performed on a daily basis by the waterworks operator and are to be recorded in operation records. This data includes the number of free chlorine residual tests performed, the overall range of free chlorine residual (highest and lowest recorded values) and the number of tests and percentage of results not meeting the minimum requirement of 0.1 mg/L free chlorine residual.

Turbidity – From Water Treatment Plant Records

Parameter	Limit (NTU)	Test Level Range	# Tests Not Meeting Requirements	Maximum Turbidity (NTU)	# Tests Required	# Tests Performed
Turbidity	Max 1.0	0.19 to .6	0	.60	365	365

Turbidity tests that did not meet requirements were the result of changing of well pump and communication issues between the water treatment plant and wells. The Environmental Project Officer (EPO) was made aware of all results.



**Saskatchewan
Ministry of
Environment**



Chemical – Health Category

All waterworks serving less than 5000 persons are required to submit water samples for SE's Chemical Health category once every 2 years. The Chemical Health category includes analysis for arsenic, barium, boron, cadmium, chromium, fluoride, lead, nitrate, selenium and uranium. The last sample for Chemical Health analysis was submitted on June 21, 2022. Sample results indicated that the provincial drinking water quality standards were not exceeded. The next sampling will be taken later in the 2024 calendar year.

All waterworks serving less than 5000 persons are required to submit water samples for SE's General Chemical category once every two years for a ground water source. The General Chemical category includes analysis for alkalinity, bicarbonate, calcium, carbonate, chloride, conductivity, hardness (as CaCO₃), magnesium, sodium, sulphate and total dissolved solids. The last sample for General Chemical analysis was required in the 2022 calendar year and submitted on June 21, 2022. Sample results indicated that there were no exceedances of the provincial aesthetic objectives* for the General Chemical category. The next sampling will be taken later in the 2024 calendar year.

*Objectives apply to certain characteristics of or substances found in water for human consumptive or hygienic use. The presence of these substances will affect the acceptance of water by consumers and/or interfere with the practice of supplying good quality water. Compliance with drinking water aesthetic objectives is not mandatory as these objectives are in the range where they do not constitute a health hazard. The aesthetic objectives for several parameters (including hardness as CaCO₃, magnesium, sodium and total dissolved solids) consider regional differences in drinking water sources and quality.

More information on water quality and sample submission performance may be obtained from:

Village of Canwood
Carmen Jean, Acting Administrator
Box 172, Canwood, SK S0J 0K0
Phone: 306-468-2016 Fax: 306-468-2805
E-mail address: canwood.town@sasktel.net



**Saskatchewan
Ministry of
Environment**

